



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI/CAN 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on October 24, 2022.

Abby Laboratories CC
11 Tassan Road
Walmer Dunes Industrial Park
Port Elizabeth 6070
South Africa
27 41 581 0512



Facility: Port Elizabeth, South Africa

Chemical/ Trade Designation	Function	Max Use	
Polymer Blends			
Abifloc 4051 [AL] [PY]	Coagulation & Flocculation	50	mg/L
Abifloc 4053 [PY]	Coagulation & Flocculation	142	mg/L
Amanzi Flocc 117 [AL] [PY]	Coagulation & Flocculation	138	mg/L
Amanzi Flocc 118 [AL] [PY]	Coagulation & Flocculation	37	mg/L
Amanzi Flocc 119 [AL] [PY]	Coagulation & Flocculation	35	mg/L
Amanzi Flocc 120 [AL] [PY]	Coagulation & Flocculation	66	mg/L
Amanzi Flocc 121 [AL] [PY]	Coagulation & Flocculation	50	mg/L
Amanzi Flocc 122 [AL] [PY]	Coagulation & Flocculation	250	mg/L
Amanzi Flocc 123 [AL]	Coagulation & Flocculation	86	mg/L
Amanzi Flocc 124 [AL]	Coagulation & Flocculation	71	mg/L
Amanzi Flocc 125 [AL]	Coagulation & Flocculation	86	mg/L
Amanzi Flocc 126 [AL]	Coagulation & Flocculation	96	mg/L
Amanzi Flocc 148 [AL] [PY]	Coagulation & Flocculation	166	mg/L

[AL] Based on an evaluation of health effects data, the level of aluminum in the finished drinking water shall not exceed 2 mg/L.

[PY] Polyamines Certified by NSF International comply with 40 CFR 141.111 requirements for percent monomer and dose.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.